WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74799
Permit No.
Basin 87

NOTICE OF INTENT NO. 39827

OWNER McCarran Partners, LLC
MAILING ADDRESS 26076 Getty Dr. Suite D
Laguna Niguel, CA 92677

ADDRESS AT WELL LOCATION 4601 W. 4th St

2. LOCATION SW 1/4 NW 1/4 Sec. 16 T 19N N/S R 19E E Washoe County

PERMIT NO. WaCo#6265 (Issued by Water Resources) | 005-212-11 (Parcel No.) | Subdivision Name

**3. WORK PERFORMED**
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

**4. PROPOSED USE**
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

**5. WELL TYPE**
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

**6. LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| On this date we abandoned the 6 5/8" well by perforating the bottom 27' from 84' up to 57' with a milis knife at 1 foot intervals and four around. We perforated above 57' about 4 different levels with one perforatiion. We pumped 60 sacks of neat cement with 5.2 gallons per sack mix using tremie pipe from bottom to top. We then finished by filling the final 10 feet with concrete mix and poured from the top. | | | | |

RECEIVED 99 JAN 11 AM 10:25 STATE ENGINEER'S OFFICE

Date started 1/7/99, 19__
Date completed 1/7/99, 19__

**7. WELL TEST DATA**

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

**8. WELL CONSTRUCTION**

Depth Drilled 84 Feet Depth Cased 84 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| Inches | Feet | Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 17.02 | .250 | 0 | 84 |
| | | | 84 | |
| | | | | |

Perforations:
Type perforation Mills Knife
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☒ Pumped ☒ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

**9. WATER LEVEL**

Static water level 64 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality

**10. DRILLER'S CERTIFICATION**

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 1/8/99

USE ADDITIONAL SHEETS IF NECESSARY