WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74815
Permit No.
Basin 105

NOTICE OF INTENT NO. 38869

1. OWNER Jim Griswold Cont.
MAILING ADDRESS 1079 Log Cabin Rd
Gardnerville NV 89410

ADDRESS AT WELL LOCATION 1757 Solitude
Gardnerville NV 89410

2. LOCATION SE¼ SE¼ Sec. 2 T. 12 N/S R. 20 E. ~~Wildf~~ Douglas County
PERMIT NO. 1220-02-061-0253 Issued by Water Resources
23-482-100 Parcel No.
Wildflower Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
overburden		0	3	3
Brown Clay		3	8	5
Course Brown Clay and Gravels		8	73	65
Brown Clay		73	92	19
Course Gravels Clay Seams		92	125	33
Course Volcanic-Sands and Gravels	XXX	125	150	25
Lost Circulation of Mud At 125 Switched to Air				

RECEIVED 99 JAN 29 AM 9:39 STATE ENGINEERS OFFICE

Date started 1-25, 1999
Date completed 1-28, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30-35	30	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	150 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	150

Perforations:
Type perforation Mill Slot
Size perforation 3x3 1/2
From 130 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 150 feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M. 30-35 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling Contractor
Address 20 Kit Kat DR Contractor
Carson City NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hall
By driller performing actual drilling on site or contractor
Date 1-28-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627