

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 74817
 Permit No. 84
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **40322**

1. OWNER Jay & Michelle Killgore ADDRESS AT WELL LOCATION 4800 Hidden Creek Rd
 MAILING ADDRESS 4800 Hidden Creek Reno, NV 89512
 2. LOCATION NW 1/4 NW 1/4 Sec. 12 T 22 N/S R 21 E Washoe County
 PERMIT NO. 077-110-25 Parcel No. Palomino V. Unit 1 12.2.1.1 par. 4 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Domestic
 Deepen Abandon Other _____ Municipal/Industrial Irrigation Monitor Test Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Perforate 4 rows from 200 feet to 305. Install trimie pipe to 350 and pump approx. 4583 lbs of neat cement pull up trimie pipe to 20 feet pump approx. 900 lbs of neat cement for 20 foot plug to surface per Matt Dillon State Water Resources Abandon				
<i>Plugging of log 49283</i>				
<i>RECEIVED ORDERED AND PAID STATE CONTRACTOR BOARD</i>				

8. WELL CONSTRUCTION
 Depth Drilled _____ Feet Depth Cased 350 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2	350

Perforations:
 Type perforation factory sawed/ air perforator
 Size perforation 3/32x3/ 1/4x2
 From 200 feet to 305 feet
 From 305 feet to 345 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 240 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. Pump & Well Service, Inc. Contractor
 Address P.O. Box 60130 Contractor
Reno, NV 89506
 Nevada contractor's license number issued by the State Contractor's Board 35387A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 2/3/99

Date started 2/1/99, 19____
 Date completed 2/2/99, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.		Time (Hours)
	Bailer	Pump	
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	Draw Down (Feet Below Static)		