WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74847
Permit No.
Basin 737

NOTICE OF INTENT NO. 37864

1. OWNER ADAM G. & KARIN M. KREMERS
MAILING ADDRESS 6700 Canoe Hill Drive
Sparks, Nevada 89436

ADDRESS AT WELL LOCATION 10210 Matterhorn
Reno, Nevada 89506

2. LOCATION SE ¼ NE ¼ Sec. 27 T. 22N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 079-450-44-78 (Parcel No.) Antelope Valley Rock Est. #3 (Subdivision Name) Lot 1

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Fine brown sand		3	18	15
Sandy brown clays		18	39	21
Brown clay		39	68	29
Brown granite sands		68	71	3
Brown sandy clay		71	105	34
Soft zone	X	105	110	5
Brown sandy clay		110	123	13
Soft medium fine brown sands	X	123	147	24

Date started 3-11-99, 19
Date completed 3-12-99, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15+		

8. WELL CONSTRUCTION
Depth Drilled 147 Feet Depth Cased 147 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	50 Feet	
8 5/8 Inches	50 Feet	147 Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	147

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 147 feet

9. WATER LEVEL
Static water level 72 feet below land surface
Artesian flow G.P.M. 15+ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date March 16, 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627