WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74848
Permit No.
Basin 103

NOTICE OF INTENT NO. 36772

1. OWNER Moline Builders
MAILING ADDRESS Hawkins Peak Rd Gardnerville, NV
ADDRESS AT WELL LOCATION 1398 Hawkins Peak Rd Gardnerville NV

2. LOCATION NE ¼ NE ¼ Sec. 1 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. (Issued by Water Resources) Parcel No. 23.483-190 Subdivision Name Wildflower

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC ☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Br Clay & Boulders		0	12	12
Sand & Gravel		12	19	7
Br Clay		19	31	12
Fine Sand		31	43	12
Br Clay		43	51	8
Fine Gravel		51	70	19
Br Sandy Clay		70	113	43
Br. Clay		113	149	36
Dark Clay		149	171	22
Br. Clay		171	183	12
Br Sandy Clay		183	275	94
Fine Sand		275	280	5
Dark Sandy Clay		280	631	351
Dark Clay		631	675	44
Course Sand	VV	675	720	45

RECEIVED 99 MAR 19 AM 10:07 STATE ENGINEER'S OFFICE

Date started Feb 25, 1999
Date completed March 19, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
425		2 hrs

8. WELL CONSTRUCTION
Depth Drilled 720 Feet Depth Cased 720 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	60 Feet
9 7/8 Inches	60 Feet	720 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+2	720

Perforations:
Type perforation Factory Mill
Size perforation 3/16 x 4
From 680 feet to 720 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 720 feet

9. WATER LEVEL
Static water level 226 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edco Exploration Inc (Contractor)
Address 7780 Curry Rd (Contractor)
Fallon, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27623 A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed [signature] (By driller performing actual drilling on site or contractor)
Date March 19 1999

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627