WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74851
Permit No.
Basin 105

NOTICE OF INTENT NO. 38886

1. OWNER Rick DeCorto Custom Homes
MAILING ADDRESS P.O. Box 2844 Minden NV. Gardnerville NV 89423 89410
ADDRESS AT WELL LOCATION 1490 Calle Pequeno Gardnerville NV 89410

2. LOCATION SW ¼ NE ¼ Sec. 32 T. 13 N/S R. 21 E. Douglas County
PERMIT NO. Issued by Water Resources
23-180-24 Parcel No.
Fish Springs Area Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	3	3
Course Cobbles and Sands		3	65	62
Course Gravels with Clay Stratas		62	90	28
Brown Dry Clay		90	105	15
Cemented Sands		105	110	5
Brown Solid Gummy Clay		110	178	68
Brown Sandy Clay Soft Sands		178	196	18
Fractured Small Gravels and Sands	XX	196	220	24

Date started 3-10, 1999
Date completed 3-12, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		5 HRS

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	220 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	220

Perforations:
Type perforation Mill Slot
Size perforation 3x 3/32
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 50 feet to 220 feet

9. WATER LEVEL
Static water level 150 feet below land surface
Artesian flow G.P.M. 20-25 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling Contractor
Address 20 Kit Kat Dr. Contractor
Carson City NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael Hack By driller performing actual drilling on site or contractor
Date 3-12-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627