

OFFICE USE ONLY
 Log No. 74858
 Permit No. 221
 Basin 1
 NOTICE OF INTENT NO 40356

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER DAN HORST ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 11785 Deodar Way
Reno, Nevada 89506

2. LOCATION NE 1/4 SW 1/4 Sec. 15 T. 21N N/S R. 19 E Washoe County
 PERMIT NO. 080-352-04 Lemmon Valley
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WELL DEEPENING:				
Fill in bottom with steel cable, pitless brass adaptor dilled up		130	135	5
Brown sandy clay		135	178	43
Soft zone (NO WATER)		178	179	1
Brown sandy clay		179	206	27
Soft zone (Maybe 1 GPM)	X	206	207	1
Brown sandy clay		207	254	47
Weathered granite		254	284	30
Fracture granite	X	284	291	7
Weathered granite		291	294	3
Fracture granite	X	294	296	2
Weathered granite		296	301	5

8. WELL CONSTRUCTION
 Depth Drilled 301 Feet Depth Cased 301 Feet

HOLE DIAMETER (BIT SIZE)
 From 6 1/8 Inches To 130 Feet 301 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5" OD		.188	0	301

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 261 feet to 301 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal deepening Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 130 feet to 301 feet

9. WATER LEVEL
 Static water level 90 feet below land surface
 Artesian flow G.P.M. 20+ P.S.I.
 Water temperature cold °F Quality clear

Date started 3-8-99, 19____
 Date completed 3-10-99, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number 0022549
 issued by the State Contractor's Board
 Nevada driller's license number 923 issued by the Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date March 11, 1999