WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74861
Permit No.
Basin 179

NOTICE OF INTENT NO. 39995

1. OWNER George Coons
MAILING ADDRESS P.O. Box 150867
East Ely, Nevada 89315
ADDRESS AT WELL LOCATION McGill Highway

2. LOCATION NE ¼ SE ¼ Sec. 30 T. 17 N/S R. 64 E. White Pine County
PERMIT NO. (Issued by Water Resources) APN 10-340-16 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Sedimentary Gravel		3	30	27
Sedimentary Sand & Gravel		30	90	60
Water Bearing Gravel	x	90	100	10
Sand & Gravel		100	140	40
Water Bearing Gravel	x	140		
& Sand			150	10
Course Sand		150	160	10

99 APR 5 PM 12:36
RECEIVED
STATE ENGINEER'S OFFICE

Date started March 19, 19 99
Date completed March 22, 19 99

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
125	65	1

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	160 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	160

Perforations:
Type perforation Factory
Size perforation 1/8" x 2½" 6 rows
From 76 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 85 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue (Contractor)
Ely, NV 89301
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
Signed Rick Lewis By Jerald D. Christiansen
(By driller performing actual drilling on site or contractor)
Date April 1, 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627