

OFFICE USE ONLY
 Log No. 74869
 Permit No. 192B
 Basin
 NOTICE OF INTENT NO. 37857

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER JEFF HAAS c/o SCHADE CONSTR. ADDRESS AT WELL LOCATION 7755 Tamara Drive
 MAILING ADDRESS P.O. Box 7182 Reno, Nevada 89510 Reno, Nevada 89506
 2. LOCATION SW 1/4 SE 1/4 Sec. 3 T 20N N/S R 19 E Washoe County
 PERMIT NO. 552-210-04 Golden Valley
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|-------------------------------------|--------------|------|-----|-----------|
| Brown clay with decomposed granite | | 0 | 1 | 1 |
| Decomposed granite | | 1 | 9 | 8 |
| Weathered granite | | 9 | 23 | 14 |
| Gray granite | | 23 | 71 | 48 |
| Weathered granite with clay streaks | | 71 | 88 | 17 |
| Gray granite | | 88 | 171 | 83 |
| Weathered granite | | 171 | 205 | 34 |
| Fracture (app 5 GPM) | X | 205 | 211 | 6 |
| Weathered granite | | 211 | 235 | 24 |
| Fracture rock | X | 235 | 255 | 20 |
| Weathered granite | | 255 | 261 | 6 |
| Fracture granite | X | 261 | 270 | 9 |
| Weathered granite | | 270 | 275 | 5 |

8. WELL CONSTRUCTION
 Depth Drilled 275 Feet Depth Cased 275 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 275 Feet
 Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 5/8 | | .188 | 0 | 275 |

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 230 feet to 270 feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 275 feet

9. WATER LEVEL
 Static water level: 180 feet below land surface
 Artesian flow G.P.M. 25+ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board: 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date March 1, 1999

Date started 2-24-99, 19.....
 Date completed 2-26-99, 19.....

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| 25+ | | |

RECEIVED
 99 MAR -3 AM 11:38
 STATE ENGINEERS OFFICE