

OFFICE USE ONLY
 Log No. 74905
 Permit No. _____
 Basin. 84

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34187
6005 HOCKBERRY RD

1. OWNER FRANK + KATIE BELL
 MAILING ADDRESS 3700 Right Hand Canyon
RENO, NV 89510
 ADDRESS AT WELL LOCATION RENO, NV 89510
 2. LOCATION NW 1/4 NW 1/4 Sec. 27 T. 22N N/S R. 21 E WASHIE County
 PERMIT NO. 000-17414 Parcel No. Palomino Valley Unit I 27-2-1-1 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>0 SAND + GRAVEL</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>SANDY CLAY</u>		<u>3</u>	<u>5.5</u>	<u>52</u>
<u>BROWN DECOMPOSED</u>				
<u>GRANITE</u>		<u>55</u>	<u>137</u>	<u>82</u>
<u>BROKEN GRANITE</u>		<u>137</u>	<u>146</u>	<u>9</u>
<u>DECOMPOSED GRANITE</u>		<u>146</u>	<u>287</u>	<u>141</u>
<u>BROWN CLAY SANDY</u>		<u>287</u>	<u>321</u>	<u>34</u>
<u>DECOMPOSED GRANITE</u>		<u>321</u>	<u>360</u>	<u>39</u>
<u>CEMENTED GRAVEL</u>	<input checked="" type="checkbox"/>	<u>360</u>	<u>400</u>	<u>40</u>
<u>DECOMPOSED GRANITE</u>		<u>400</u>	<u>422</u>	<u>22</u>

8. WELL CONSTRUCTION
 Depth Drilled 422 Feet Depth Cased 422 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10.625 Inches ~~10~~ Feet 422 Feet
 To _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>.188</u>	<u>27</u>	<u>422</u>

Perforations:
 Type perforation MILLED SLOT
 Size perforation .125
 From 360 feet to 400 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 422 feet

9. WATER LEVEL
 Static water level 230 feet below land surface
 Artesian flow N.O. G.P.M. _____ P.S.I. _____
 Water temperature 60.0 °F Quality G.O.C.D.

Date started 2-2- 19 99
 Date completed 2-5- 19 99

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>		<u>1</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name POINTS WEST DRILLING Contractor
 Address P.O. Box 178 Contractor
WEST POINT, CA 95255
 Nevada contractor's license number issued by the State Contractor's Board 39825
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1974
 Signed Jimmy L. Ouellet
 By driller performing actual drilling on site or contractor
 Date 2-5-99