WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74915
Permit No.
Basin 203

NOTICE OF INTENT NO. 15806

1. OWNER Rex Shurtz
MAILING ADDRESS P.O. Box 601 Caliente NV 89008
ADDRESS AT WELL LOCATION 8 miles North of Caliente on Tare Street

2. LOCATION S/W ¼ N/W ¼ Sec. 3 T. 3 N/S R. 67 E. Lincoln County
PERMIT NO. — (Issued by Water Resources) Parcel No. 13-042-35 Subdivision Name Highland Knolls

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand - Boulders		0	53	53
Clay - Boulders		53	170	117
Sand - Boulders		170	179	9
Clay - Sand	X	179	255	76
gravel - Boulders	X	255	270	15
Clay		270	280	10

Date started 4-8-99, 19
Date completed 4-11-99, 19

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
14	2	5

8. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	280 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		Sch 40 PVC	0	280

Perforations:
Type perforation Factory
Size perforation 1/4" x 3"
From 180 feet to 200 feet
From 220 feet to 240 feet
From 260 feet to 280 feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 280 feet

9. WATER LEVEL
Static water level 186 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps (Contractor)
Address P.O. Box 54 Hiko NV 89017 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike Davis (By driller performing actual drilling on site or contractor)
Date 4-20-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627