WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74922
Permit No.
Basin 162

NOTICE OF INTENT NO. 18010

1. OWNER Dale & Catherine Mathews -RKD
MAILING ADDRESS Box 5267
Pahrump, NV 89041 NW

ADDRESS AT WELL LOCATION
350 W. Joy St
Pahrump, NV 89048

2. LOCATION NW ¼ ~~SE~~ ¼ Sec. 16 T. 20S N/S R. 53 E. Nye County

PERMIT NO. 35-331-11 (Issued by Water Resources) | 35-331-11 (Parcel No.) | None (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Grey Clay		4	12	3
Brown Clay		12	55	43
Soft Grey Clay	X	55	62	7
Brown Clay		62	92	30
Hard strip		92	93	6
Soft brown clay	X	98	113	20
Hard (soft caliche)		113	124	6
Brown clay		124	162	33
Soft brown clay	X	162	169	7
Brown clay		169	188	19
Soft brown clay	X	188	195	7
Brown clay		195	100	5

Date started 4-26-99, 19
Date completed 4-28-99, 19

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	-0-	15 min

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	200 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17#	.188	0	200

Perforations:
Type perforation TORCH CUT
Size perforation 3/4" x 8"
From feet to feet
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 0 feet to 50 feet

9. WATER LEVEL
Static water level 44 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg WELL Drilling (Contractor)
Address 1060 W. Basin Ave (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 7434
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
Signed Charles Nyberg by RKD
By driller performing actual drilling on site or contractor
Date 5-5-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627