

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19043

1. OWNER Jerry Stalmer ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3480 W. Medicine Man Rd 3480 W. Medicine Man
Pahrump, Nevada 89048 Pahrump, Nevada 89048
 2. LOCATION NW 1/4 SE 1/4 Sec 13 T 20 S N/S R. 53 E E Nye County
 PERMIT NO. 28-652-05 Charleston Park Ranchos Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG


Material	Water Strata	From	To	Thick-ness
top soil		0'	5'	5'
white clay		5'	25'	20'
green clay		25'	40'	15'
caliche		40'	45'	5'
white clay		45'	60'	15'
brown clay		60'	100'	40'
caliche		100'	110'	10'
white clay		110'	120'	10'
brown clay		120'	140'	20'

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.625</u>	<u>4.33</u>	<u>.316</u>	<u>0'</u>	<u>140'</u>

Perforations:
 Type perforation Saw cut
 Size perforation 1/8" x 3"
 From 100 feet to 140 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50' feet to 140' feet



9. WATER LEVEL
 Static water level 51 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 4/23, 1999
 Date completed 4/24, 1999

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ron Nailort Drilling Contractor
 Address P.O. Box 265 Contractor
Pahrump, Nevada
 Nevada contractor's license number issued by the State Contractor's Board 0035704
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 2116
 Signed Forrest Lohr
 By driller performing actual drilling on site or contractor
 Date 4/28/99

