

OFFICE USE ONLY
 Log No. 74977
 Permit No. _____
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32249

1. OWNER TAB ADDRESS AT WELL LOCATION En 20 Wash
 MAILING ADDRESS 3617 N 5th St N. Washington
NLV NV
 2. LOCATION SW 1/4 S 1/2 Sec. 19 T 20 N R 62 E Clark County
 PERMIT NO. DW 10922 Issued by Water Resources Parcel No. 140-30-596-003 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE dewater WELL TYPE
 Domestic Irrigation Test Cable Rotary RVC
 Municipal/Industrial Monitor Stock Air Other Bucket

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>sand + dirt</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>silty sand</u>		<u>3</u>	<u>6</u>	<u>3</u>
<u>sandy clays</u>		<u>6</u>	<u>30</u>	<u>24</u>

8. WELL CONSTRUCTION
 Depth Drilled 30 Feet Depth Cased 30 Feet
 HOLE DIAMETER (BIT SIZE)
 From 24 Inches 2 Feet 30 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>PVC</u>	<u>Sch 40</u>	<u>0</u>	<u>30</u>

Perforations:
 Type perforation Slot
 Size perforation 0.32
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From 10 feet to 30 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 0 feet to 30 feet

9. WATER LEVEL
 Static water level 8 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Good

Date started 5-5-99, 19_____
 Date completed _____, 19_____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name CDC Contractor
 Address 536 E. Mainland Contractor
Clark
 Nevada contractor's license number issued by the State Contractor's Board 31246
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller W/1968
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 5-4-99