

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32249

1. OWNER TAB ADDRESS AT WELL LOCATION In L.G. WASH
 MAILING ADDRESS S. Washington Bldg
 2. LOCATION NLV NV ADDRESS NEAR E CURB County _____
 PERMIT NO. 21092 Issued by Water Resources Parcel No. 140-32699 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE dewater WELL TYPE
 Domestic Irrigation Test Cable Rotary RVC
 Municipal/Industrial Monitor Stock Air Other NY


6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Dirt & Sand</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Sand & gravel</u>		<u>3</u>	<u>7</u>	<u>4</u>
<u>Fine Sand</u>		<u>7</u>	<u>12</u>	<u>5</u>
<u>Silty Clay w/ Sands</u>		<u>12</u>	<u>30</u>	<u>18</u>

8. WELL CONSTRUCTION
 Depth Drilled 30 Feet Depth Cased 30 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Inches To 30 Feet
 From 0 Inches To _____ Feet
 From _____ Inches To _____ Feet
 From _____ Inches To _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>PVC</u>	<u>sch 40</u>	<u>0</u>	<u>30</u>

 Perforations:
 Type perforation slot
 Size perforation .032
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From 10 feet to 30 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No 30
 From _____ feet to _____ feet



Date started 3-5-99, 19____
 Date completed 3-5-99, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 0 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature 60 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge
 Name GD Contractor
 Address 536 E Midland Contractor
 Nevada contractor's license number 31246 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1968
 Signed GD By driller performing actual drilling on site or contractor
 Date 3-5-99