WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74993
Permit No.
Basin 212

NOTICE OF INTENT NO. 32249

1. OWNER TAB Contractors
MAILING ADDRESS 3617 N 5th NLV NV
ADDRESS AT WELL LOCATION In L.V. Wash S. of Washington Bonanza

2. LOCATION SW ¼ S ¼ Sec 19 T 20 N S R 62 E Clark County
PERMIT NO. DW1092.B 2 (Issued by Water Resources) 140-32-696-201 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE dewater
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Bucket

6. LITHOLOGIC LOG

| Material | Water-Strata | From | To | Thickness |
|---|---|---|---|---|
| Dirt + Sand | | 0 | 3 | 3 |
| Sand + gravel | | 3 | 7 | 4 |
| Fine Sand | | 7 | 13 | 6 |
| Silty Clay w Sands | | 13 | 30 | 17 |

DOWR/DWR Received MAR 31 1999 NEVADA OFFICE

Date started 3-5-99, 19
Date completed 3-5, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| | | | |

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 24 Inches | 0 Feet | 30 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 | PVC | Sch 40 | 0 | 30 |

Perforations:
Type perforation Slot
Size perforation .032
From feet to feet
From feet to feet
From 10 feet to 30 feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 0 feet to 30 feet

9. WATER LEVEL
Static water level 4 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CoDC (Contractor)
Address 536 E Maitland (Contractor) 91761
Nevada contractor's license number issued by the State Contractor's Board 31246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1968
Signed [signature] By driller performing actual drilling on site or contractor
Date 3-31-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627