

Log No. 73011
 Permit No. 103
 Basin 131621

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 131621

1. OWNER PAT CORBITT ADDRESS AT WELL LOCATION 181 HORSESHOE BEND RD
 MAILING ADDRESS 181 HORSESHOE BEND RD GV, NV 89410
 2. LOCATION NW 1/4 NW 1/4 Sec. 6 T. 11 S R. 21 E DOUGLAS County
 PERMIT NO. 35-330-02 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Clayey loam</u>		<u>0</u>	<u>12</u>	<u>12</u>
<u>Blended to 48'</u>		<u>12</u>	<u>48</u>	<u>36</u>
<u>Clayey cobble & large gravel</u>		<u>48</u>	<u>170</u>	<u>122</u>
<u>Brown clay</u>				<u>148</u>
<u>156'</u>				
<u>Same as 48-170</u>		<u>170</u>	<u>240</u>	<u>70</u>
<u>w thin sands</u>				
		<u>240</u>	<u>305</u>	<u>65</u>
<u>Sandy gravel</u>	<u>X</u>	<u>305</u>	<u>400</u>	<u>95</u>
<u>cobble w thin gravel all w some clay</u>				

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 400 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 60 Feet
10 3/8 Inches 60 Feet 400 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13</u>	<u>.188</u>	<u>+2</u>	<u>400</u>

Perforations:
 Type perforation SAWCUT
 Size perforation 3x3/32
 From 340 feet to 400 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 51 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 51 feet to 400 feet

9. WATER LEVEL
 Static water level 140 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature COLD °F Quality _____

Date started 4/29/98
 Date completed 5/15/98

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA DRILLING, INC Contractor
 Address 75 LEWENS CRK RD Contractor
WASHOE VALLEY, NV 89704
 Nevada contractor's license number 13697A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1476
 Division of Water Resources the on-site driller
 Signed Joe Leach
 By driller performing actual drilling on site or contractor
 Date 7/30/98