WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA 98-8
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75023
Permit No.
Basin 61

NOTICE OF INTENT NO. 39515

1. OWNER Barrick Goldstrike Mines Inc
MAILING ADDRESS PO Box 29 Elko, NV 89803
ADDRESS AT WELL LOCATION Same

2. LOCATION SW ¼ SE ¼ Sec. 18 T. 36 N/S R. 50 E. Eureka County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
98-8				
Silt + Gravel / Brn.		0	18	18
Silty Sand + clay / Brn		18	54	36
Silty Sand / Rd-Brn		54	151	97
Carlin Ash / Grey-Brn (1) Soft		151	175	24
Carlin Ash / Grey-Brn Soft		175	179	

Date started 9/4, 1998
Date completed 10/2, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Piezometer		
NOT pumped.		

8. WELL CONSTRUCTION
Depth Drilled 179 Feet Depth Cased 175 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 5/8 Inches	0 Feet	179 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	.698	.154	+3	100
2.375	.698	.154	+3	175

Perforations:
Type perforation Factory cut
Size perforation .020
From 90 feet to 100 feet
From 165 feet to 175 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 86'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 88'-100' feet to 163'-176' feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature 60.1 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bart Longyear (Contractor)
Address 7773 W. Sellon Ln. Peoria, AZ. 85345 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2106
Signed Daniel Casey (By driller performing actual drilling on site or contractor)
Date 10/21/98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627