

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38874

1. OWNER Dave Oneil ADDRESS AT WELL LOCATION 1511 Carlson
MAILING ADDRESS Gardnerville NV 89423

2. LOCATION SW 1/4 NE 1/4 Sec. 32 T. 13 N S R. 21 E Douglas County
PERMIT NO. 62834 23-170-24 Parcel No. Fish Springs Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Hard Pack</u>		<u>0</u>	<u>4</u>	<u>4</u>
<u>Coarse 1/4" Gravel</u>		<u>4</u>	<u>68</u>	<u>64</u>
<u>Brown Clay</u>		<u>68</u>	<u>74</u>	<u>6</u>
<u>Small obsidian Sands and clay seams</u>	<u>X</u>	<u>74</u>	<u>165</u>	<u>91</u>
<u>Gray Clay</u>		<u>165</u>	<u>180</u>	<u>15</u>
<u>Brown Gray Clay</u>		<u>180</u>	<u>203</u>	<u>23</u>
<u>Fractured Gravels orange and Rusty Gravels with green Stained Rock</u>	<u>XXX</u>	<u>203</u>	<u>240</u>	<u>37</u>

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)
From 10 3/4 Inches To 0 Feet 240 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>240</u>

Perforations:
Type perforation M.I. slot
Size perforation 3 x 3/32
From 160 feet to 180 feet
From 200 feet to 240 feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type:
Depth of Seal 55 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 55 feet to 240 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow 35 G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY Well Drilling Contractor
Address 20 Kit Kat DR Carson City NV Contractor
Nevada contractor's license number issued by the State Contractor's Board 42775 (4775)
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael Heck
By driller performing actual drilling on site or contractor
Date 2-5-99

Date started 2-1, 1999
Date completed 2-4, 1999

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>35</u>	<u>75</u>	<u>3 1/2 HRS</u>