WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76029
Permit No.
Basin 153

NOTICE OF INTENT NO. 32375

1. OWNER RITA WILLIAMSEN & R.O. BONNHAM
MAILING ADDRESS EUREKA NEV. 89316 BOX 206
ADDRESS AT WELL LOCATION N 39.744493 W115.924699 NAD27

2. LOCATION SW ¼ NW ¼ Sec. 32 T. 22 N/S R. 54 E. EUREKA County

PERMIT NO. ~~27399~~ 28641 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	2	2
Sand Gravel		2	24	22
CLAY, SOME LAYERS OF FINE BLACK SAND.		24	133	109
BLACK Sand Gravel	15	133	148	15
BLACK CLAY		148	155	7
BLACK SAND GRAVEL	15	155	170	15
CLAY		170	175	5
BLACK SAND & GRAVEL	4	175	179	4
CLAY WITH SOME BLACK SAND LAYERS		179	230	51
SAND & GRAVEL	6	230	236	6
CLAY		236	240	4
SAND & GRAVEL	4	240	244	4
CLAY		244	248	4
SAND & GRAVEL	10	248	258	10
CLAY		258	301	43
HARD BROWN SAND STONE	28?	301	329	28
SOFT CLAY		329	338	9
HARD BROWN SAND STONE.	23	338	361	23

RECEIVED 98 JAN -9 AM 10:04 STATE ENGINEER'S OFFICE

Date started 12-6, 1998
Date completed 12-20, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 361 Feet Depth Cased 361 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
27 Inches		TOP Feet	361 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16"		¼"	0	261
12"		¼"	261	361

Perforations:
Type perforation ROSCOE MOSS
Size perforation ⅛
From 138 feet to 178 feet
From 230 feet to 260 feet
From 301 feet to 361 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From TOP feet to 361' feet

9. WATER LEVEL
Static water level 88 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WALTER PLASKETT (Contractor)
Address BOX 10 (Contractor)
EUREKA, NEV. 89316
Nevada contractor's license number issued by the State Contractor's Board 11882
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 635
Signed Jonas E. Groth (By driller performing actual drilling on site or contractor)
Date 1-4-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627