

OFFICE USE ONLY
Log No. 5031
Permit No. 87
Basin. 16568

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16568

1. OWNER WASHOE COUNTY DEPT. OF WATER RESOURCES ADDRESS AT WELL LOCATION SE CORNER OF THE INTERSECTION OF DOUGLAS DIAMOND + DOUBLE 'R' BLVD
MAILING ADDRESS POB. 11130
RENO, NV 89502-0037
2. LOCATION NW 1/4 SE 1/4 Sec 5 T. 18 N. S. R. 20 E WASHOE County
PERMIT NO. South Meadows Subdivision Name
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>BR OLIGAMIC SILTY SAND (SM)</u>		<u>0.0</u>	<u>1.0</u>	<u>1.0</u>
<u>DK BR CLAYEY SAND (SU) w/ GRAVELS</u>		<u>1.0</u>	<u>3.0</u>	<u>2.0</u>
<u>COLOR CHANGE TO BROWN</u>		<u>3.0</u>	<u>8.0</u>	<u>5.0</u>
<u>WATER LEVEL (NOT STABILIZED)</u>	<u>8.0</u>			
<u>BR SAND (SU)</u>		<u>8.0</u>	<u>18.0</u>	<u>10.0</u>
<u>EOB @ 18.0</u>				

8. WELL CONSTRUCTION
Depth Drilled 18.0 Feet Depth Cased 18.0 Feet
HOLE DIAMETER (BIT SIZE)
From 7 Inches 0 Feet 18 Feet
Inches 0 Feet 0 Feet
Inches 0 Feet 0 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2 SCREEN</u>	<u>0.70</u>	<u>0.308</u>	<u>3.0</u>	<u>18.0</u>
<u>2 OLIGAMIC</u>			<u>0.0</u>	<u>3.0</u>

Perforations:
Type perforation SLOTTED
Size perforation 0.020
From 18.0 feet to 3.0 feet
From 0.0 feet to 0.0 feet
Surface Seal: Yes No Seal Type:
Depth of Seal 1-2' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 2.0 feet to 18.0 feet

Date started 12-28-78 1978
Date completed 12-28-78 1978

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
Static water level: 8.0 - 9.0 feet below land surface
Artesian flow: NO G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DALE LEHMAN Contractor
Address PEROWE & ASSOCIATES Contractor
520 EDISON WAY RENO NV 89502
Nevada contractor's license number issued by the State Contractor's Board:
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: M-1976
Signed Dale Lehman
By driller performing actual drilling on site or contractor
Date 1/19/99