WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75034
Permit No. 64522
Basin 230

NOTICE OF INTENT NO. 17781

1. OWNER John Acomb
MAILING ADDRESS 20 State Road #4
Los Alamos, NM 87544

ADDRESS AT WELL LOCATION Farm Road
Amargosa Valley, NV 89020

2. LOCATION NE ¼ NE ¼ Sec. 15 T 16 N/S R 48 E NYE County
PERMIT NO. 64522 (Issued by Water Resources) Parcel No. 19-641-01 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil + Sand		0	25	25
Clay		25	45	20
Sand + Clay Mix		45	55	10
Coarse Sand + Gravel		55	60	5
Sand + Clay beds		60	80	20
Clay + Gravel beds		80	118	38
Gravel	1st	118	130	12
Cemented Sand		130	144	14
Clay		144	150	6
Cemented Sand		150	160	10
Gravel + Clay	2nd	160	175	15
Gravel		175	200	25
Bottom of Well				

Date started 4-22, 1999
Date completed 4-26, 1999

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200' Feet Depth Cased 200' Feet

HOLE DIAMETER (BIT SIZE)
0 From 200' To
12¼ Inches 0 Feet 200 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8" Steel Casing		.250	0	200'

Perforations:
Type perforation Machined
Size perforation 3/16 x 3
From 120' feet to 140' feet
From 180' feet to 200' feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50' feet to 200' feet

9. WATER LEVEL
Static water level 107' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 76 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cook Drilling Co. (Contractor)
Address HC 69 Box 450 (Contractor)
Amargosa Valley, NV 89020
Nevada contractor's license number issued by the State Contractor's Board 53746-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 830
Signed Dave Rau (By driller performing actual drilling on site or contractor)
Date May 17, 1999

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627