

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18141

1. OWNER **Jerry Povidlo** ADDRESS AT WELL LOCATION **5940 E. Doubletree**  
 MAILING ADDRESS **1210 N. Arnold** Las Vegas, NV

2. LOCATION **SE 1/4 NW 1/4 Sec. 10 2 T 21S 20** N/S R **1E 52** E Nye County  
 PERMIT NO. **43-071-16** Parcel No. **Cottonwood** Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Domestic  Irrigation  Test  
 Deepen  Abandon  Other  Municipal/Industrial  Monitor  Stock

4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Loam		0	15	15
Rock		15	80	65
Rock		80	95	15
Rock	x	95	100	5
Rock	x	100	150	50
Rock	x	150	225	75
Rock	x	225	230	5

8. WELL CONSTRUCTION

Depth Drilled **230** Feet Depth Cased **230** Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<b>11</b>	<b>0</b>	<b>230</b>	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6 5/8</b>	<b>3.7</b>	<b>.280</b>	<b>0</b>	<b>230</b>

Perforations:  
 Type perforation **Sawcut**  
 Size perforation **6 5/8**

From	feet to	feet
<b>205</b>	<b>230</b>	

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Gravel Packed:  Yes  No  
 From **50** feet to **230** feet

9. WATER LEVEL

Static water level **95** feet below and surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature **Cool** °F Quality **Good**

Date started **3/22/99**, 19\_\_\_\_  
 Date completed **3/22/99**, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<b>.5</b>	<b>n/a</b>	<b>.50</b>	

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.** Contractor  
 Address **2301 Winery Road, Suite 2** Contractor  
**Pahrump, NV 89048**

Nevada contractor's license number issued by the State Contractor's Board **40277**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed **Jerry Strickland**  
 By driller performing actual drilling on-site or contractor  
 Date **3.24.99**

