

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 75082
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18693

1. OWNER McCOY, OTTO ADDRESS AT WELL LOCATION 6210 S HAWKINS WAY
 MAILING ADDRESS 6210 S HAWKINS WAY
PAHRUMP, NV 89048

2. LOCATION NE 1/4 NE 1/4 Sec. 18 T 21S N/S R 54E E NYE County
 PERMIT NO. LOT 1 Insured by Water Resources NW3 Parcel No. 45-211-11 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY & CALICHIE		0	60	
CALICHIE	WB	60	80	20
CLAY		80	95	15
CALICHIE	WB	95	115	20
CLAY		115	123	8
CALICHIE	WB	123	138	15
CLAY		138	151	13
CALICHIE	WB	151	160	9

WELL IS A 6" PVC CASING WITH 7' OF 8" STEEL SLEEVE FROM +1' TO 6' SNC 11/12/2009

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 160 Feet
 10.25 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.625</u>	<u>3.63</u>	<u>.280</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation SAW CUT
 Size perforation 1/8 X 3

From 100 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 _____
 Neat Cement
 Cement Grout
 Concrete Grout

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 56 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 3/8/99 19____
 Date completed 3/12/99 19____

7. WELL TEST DATA

TEST METHOD:	Bailey		Pump		Air Lift	
	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
 Address P.O. BOX 4220 Contractor
PAHRUMP, NV, 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Owen
 By driller performing actual drilling on-site or contractor
 Date 3/22/99