WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75099
Permit No. 63954-T
Basin 117

NOTICE OF INTENT NO. 17822

1. OWNER Jame & Christine Boyce
MAILING ADDRESS PO Box 1766
Bishop, Ca. 93515

ADDRESS AT WELL LOCATION The SE corner of said sec. 4, bears S 19°,55', 01E, a distance of 5470.01.

2. LOCATION SW ¼ SE ¼ Sec. 22 T. 02 N/S R 35 E County
PERMIT NO. 63954-T Issued by Water Resources
M.D.B.&M. 007-Page No. 01
or at a point from which to
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other reverse

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	80	80
sand & gravel		80	90	10
sand		90	180	90
sand & gravel		180	220	40
sand, gravel & rock		220	270	50
sand & gravel		270	280	10
sand, gravel & rock		280	510	230
sand & gravel		510	540	30

RECEIVED 89 FEB 22 AM 10:40 STATE ENGINEER'S OFFICE

Date started April 4th, 19 98
Date completed April 4th, 19 98

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Constant	3,000	165	4 hours

8. WELL CONSTRUCTION
Depth Drilled 540 Feet Depth Cased 520 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
36	Inches	0	Feet	50	Feet
26	Inches	50	Feet	540	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16"			+2	520

Perforations:
Type perforation mill slot
Size perforation .098
From 200 feet to 510 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 540 feet

9. WATER LEVEL
Static water level 117.70 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 70 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bakersfield Well & Pump (Contractor)
Address 7212 Fruitvale Ave. (Contractor)
Bakersfield, Ca. 93308

Nevada contractor's license number issued by the State Contractor's Board 0037248
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1993
Signed [redacted] (By driller performing actual drilling on site or contractor)
Date May 10th 1998

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627