

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. **75128**
Permit No. **212**
Basin **212**

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

NOTICE OF INTENT NO. **18281**

1. OWNER Chapman Realty
MAILING ADDRESS 3370 Ocean Park Blvd
Suite 3030, Santa Monica, CA 90405
ADDRESS AT WELL LOCATION 381, 367, 315
S. Delmar Blvd, Las Vegas, NV

2. LOCATION SW 1/4 NW 1/4 Sec. 31 T. 20 N. R. 61 E Clark County
PERMIT NO. NV-2757-139-31-201-001-003, 4-004 Parcel No.
Issued by Water Resources Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. Domestic Municipal/Industrial Irrigation Test Stock Cable Rotary RVC
 Monitor Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt		0	0.5	6.5
SANDY SILT		0.5	2	1.5
SLTY CLAY		2	3	1
CLAYEY SILT		3	5	2
SLTY CLAY		5	8	3
CLAYE		8	10	2
CLAYEY SILT		10	12	2
SAND		12	15	3
CLAYEY SAND		15	23	8
SAND		23	25	2

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 23 Feet
HOLE DIAMETER (BIT SIZE)
From To
5.25 Inches 0 Feet 25 Feet
Inches Feet Feet Feet
Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	4.70	0.154	0	23

Performers: Factory Stamped PVC
Type perforation 0.125"
Size perforation 23
From 10 feet to 23 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 6-6 Pumped Cement Grout
Placement Method: Poured Concrete Grout
Gravel Packed: Yes No
From 8 feet to 25 feet

9. WATER LEVEL
Static water level: NA feet below land surface
Artesian flow: _____ G.P.M. P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Wilson Contractor
1731 PLEASANT ROAD SUITE H
Address Las Vegas, NV 89119
Nevada contractor's license number 0834757
Nevada driller's license number issued by the State Contractor's Board M-1589
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: _____
Signed Don Wilson
By driller performing actual drilling on site or contractor 3/11/99

Date started 1/22 19 79
Date completed 1/22 19 79
7. WELL TEST DATA
TEST METHOD: Bailor Pump Air Lift
G.P.M. Draw Down (Feet Below Static) Time (Hours)