

OFFICE USE ONLY  
 Log No. **75130**  
 Permit No. \_\_\_\_\_  
 Basin. **162**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **19039**

1. OWNER Lauri Harrison ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 1591 W. Sloan St. 1591 W. Sloan St.  
Pahrump Nevada Pahrump, Nevada  
 2. LOCATION SE 1/4 NW 1/4 Sec. 20 T. 19 N. R. 53 E. Nye County  
 PERMIT NO. 29-385-03 Crystalice Estates Subdivision Name  
 Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
silt		0'	20'	20'
white clay		20'	30'	10'
silt		30'	40'	10'
sand & gravel		40'	45'	5'
clay		45'	50'	5'
sand		50'	55'	5'
clay		55'	65'	10'
gravel		65'	70'	5'
brown clay		70'	90'	20'
sand		90'	110'	20'
sand & gravel		110'	140'	30'

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	4.33	.316	0'	140'

Perforations:  
 Type perforation Sand cut  
 Size perforation 1 7/8" x 3"  
 From 100 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50' feet to 140' feet

9. WATER LEVEL  
 Static water level 61 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Ron Nailon Drilling Contractor  
 Address P.O. Box 265 Contractor  
Pahrump, Nevada 89041  
 Nevada contractor's license number 2035704  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 2116  
 Division of Water Resources, the on-site driller  
 Signed Forest LaRue  
 By driller performing actual drilling on site or contractor  
 Date 3/21/99

Date started March 11 1999  
 Date completed March 18 1999

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED  
 09 APR 4 AM 11:23  
 STATE ENGINEERING DIVISION

