

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 75152
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18438

1. OWNER Sarah and Ronald Brown ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 6691 S. Conestoga 6691 S. Conestoga
Pahrump, NV 89048
 2. LOCATION SW 1/4 NW 1/4 Sec. 13 T 21S N/S R 53E E Nye County _____
 PERMIT NO. 44-603-13 Conestoga Country Estates
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG


Material	Water Strata	From	To	Thickness
brown clay		0	4	4
grey clay		4	8	4
brown sandy loam and calache		8	17	9
light brown calache		17	19	2
light brown loam		19	33	14
grey calache		33	34	1
See next line		34	59	25
light brown loam and calache strings				
See next line	x	59	65	6
light brown loam and calache strings				
light brown loam	x	65	80	15
grey calache and sandy loam	x	80	105	25
grey loam	x	105	112	7
grey loam	x	112	140	28

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
11 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
 Type perforation sawcut
 Size perforation .188
 From 100 feet to 140 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 140 feet



Date started 3/3/99 _____ 19
 Date completed 3/3/99 _____ 19

9. WATER LEVEL
 Static water level 59 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift G.P.M. _____	<u>na</u>	<u>.50</u>
_____	_____	_____
_____	_____	_____
_____	_____	_____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Strickland Construction Co., Inc. Contractor
 Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 3.9.99

