

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
 Log No. 75154  
 Permit No. 21206  
 Basin. 203

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 19162

1. OWNER Bill McInnis ADDRESS AT WELL LOCATION ZW Ranch  
 MAILING ADDRESS 6520 N. Tenaya Way  
Las Vegas NV. 89131

2. LOCATION SE 1/4 SW 1/4 Sec 2 T. 3 N. OR 67 E. Lincoln County  
 PERMIT NO. 21206 013-03-021  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay, sand		0	55	55
Clay (Blue)		55	110	55
Sand, Gravel	X	110	127	17
Sand, Gravel, cobbles	X	127	148	21
Clay (Red)		148	160	12

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
24 Inches 0 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16"	32	.250	0	160

Perforations:  
 Type perforation Wire Wand Screen  
 Size perforation 1/8 Slot  
 From 110 feet to 150 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 160 feet

9. WATER LEVEL  
 Static water level 53 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started Nov. 5, 1998  
 Date completed Nov. 8, 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>350</u>	<u>7 60'</u>	<u>12 hrs.</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Steven Anzalone Contractor  
 Address 1225 E. 600 S. Contractor  
Enterprise Ut. 84725  
 Nevada contractor's license number issued by the State Contractor's Board 18239  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 811

Signed Steven Anzalone Bryan Anzalone  
 By driller performing actual drilling on site or contractor  
 Date Mar. 11, 99

