

OFFICE USE ONLY
 Log No. 75169
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17295

1. OWNER Gene Warholio ADDRESS AT WELL LOCATION Woodchips Street
 MAILING ADDRESS Woodchips - Pahrump, NV Pahrump, NV 89041
 2. LOCATION NW $\frac{1}{4}$ SE $\frac{1}{4}$ Sec. 18S T. 20S N/S R. 53E E Nye County
 PERMIT NO. 39-231-16 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay		0	3	3
Grey clay		3	22	19
Caliche		22	24	2
Grey clay	X	24	80	56
Light Brown clay	X	80	118	38
Caliche	X	118	122	4
Brown clay	X	122	140	18

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12</u>	<u>0</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Factory
 Size perforation Saw Cut
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From 100 feet to 130 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 54 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality good

Date started April 28, 1998
 Date completed April 30, 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>30</u>	<u>50</u>	<u>1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Larry Jenkins Contractor
 Address P.O. Box 3392
Pahrump, NV 89041
 Nevada contractor's license number 0035901
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
 Signed Larry Jenkins
 By driller performing actual drilling on site or contractor
 Date _____