SEC 04 DBDA

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75172
Permit No. 79860
Basin 162

NOTICE OF INTENT NO 17308

1. OWNER A.N.C. Roofing
MAILING ADDRESS Pah. NV. NW 4
ADDRESS AT WELL LOCATION 280 W. STAGE COACH ROAD Stage Stop Street.

2. LOCATION NE ¼ SE ¼ Sec. 4 T. 20 S N/S R. 53 E N/E County
PERMIT NO. 35-094-12 CORRECT
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sandy Soil | | 0 | 3 | 3 |
| Brown Clay | | 3 | 7 | 4 |
| Grey Clay | | 7 | 15 | 8 |
| Brown Clay | | 15 | 50 | 35 |
| Caliche | | 50 | 53 | 3 |
| Brown Clay | x | 53 | 85 | 32 |
| Grey Clay | x | 85 | 140 | 55 |

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 12 Inches | 0 Feet | 140 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 | PVC | Sed 40 | 0 | 140 |

Perforations:
Type perforation Saw
Size perforation ⅛ x 6
From 100 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 140 feet

WATER LEVEL
Static water level 55 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

Post-it™ Fax Note 7671

| | |
|---|---|
| Date | # of pages ▶ |
| To LAS VEGAS | From TOM G |
| Co./Dept. | Co. |
| Phone # | Phone # 684-2847 |
| Fax # 486-2781 | Fax # 684-2810 |

NOTE CHANGES - DATABASE OK

Date started 6-25, 1998
Date completed 6-26, 1998

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 30 | 4 | ½ |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Larry's Water Well Service
Contractor
Address Po. Box 3392 Pah. NV. 89041
Contractor

Nevada contractor's license number issued by the State Contractor's Board 0035901
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
Signed Larry Jenkins
By driller performing actual drilling on site or contractor
Date 6-27-98

DCNR/DWR RECEIVED

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

DEC 13 2010

Faxed 6-26-98

LAS VEGAS OFFICE