WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75177
Permit No.
Basin 162

NOTICE OF INTENT NO. 40692

1. OWNER Shelley Floyd
MAILING ADDRESS 5600 E. Doubletree Rd, Pahrump, Nevada 89048
ADDRESS AT WELL LOCATION 5600 E Doubletree Rd Pahrump, NV 89048

2. LOCATION NW ¼ SE ¼ Sec. 16 T. 21 N S R 53 E Nye County
PERMIT NO. ____ Issued by Water Resources | 43-081-20 Parcel No. | Cottonwoods at Hafen Ranch Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silt		0'	15'	15'
sand & gravel		15'	25'	10'
cemented gravel		25'	35'	10'
sand & gravel		35'	40'	5'
cemented gravel		40'	50'	10'
sand / clay		50'	65'	15'
caliche		65'	75'	10'
clay		75'	80'	5'
cemented silt		80'	85	5'
gravel		85'	95'	10'
sand / gravel		95'	100'	5'
clay / sand		100'	110'	10'
cemented silt		110'	115'	5'
clay		115'	140'	25'

RECEIVED 99 MAR 22 PM 12:25 STATE ENGINEER'S OFFICE

DONALD W. Received APR 3 1999 LAS VEGAS OFFICE

Date started February 19, 1999
Date completed February 24, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	4.33	.316	0'	140'

Perforations:
Type perforation Saw cut
Size perforation 1/8" X 3"
From 100 feet to 140 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140' feet

9. WATER LEVEL
Static water level 63' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ron Naillon Drilling Contractor
Address P.O. Box 265 Contractor
Pahrump, Nevada 89041
Nevada contractor's license number issued by the State Contractor's Board 0035704
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116
Signed Forrest LaRue
By driller performing actual drilling on site or contractor
Date 3/16/99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627