


Log No. **75180**  
 Permit No. \_\_\_\_\_  
 Basin **162**



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13009

1. OWNER Alberto & Silvia Juarez ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 1617 Piper Ave 2151 W. Bluebird St  
North Las Vegas, NV Pahrump, NV  
 2. LOCATION NE 1/4 NE 1/4 Sec 19 T 19S N/S R 53 E Nye County \_\_\_\_\_  
 PERMIT NO. 29-373-02 29-373-02 Crystallaire Estates, Lot 230  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_


6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Brown clay		4	36	32
Grey clay		36	40	4
Brown clay		40	68	23
Grey clay		68	74	6
Brown clay	x	74	96	22
Cemented gravel		96	104	8
Clay w/small gravel	x	104	126	22
Cemented gravel		126	135	11
Brown clay		135	142	7
Cemented gravel		142	148	6
Brown clay w/gravel	x	148	160	12

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
3	17#	.183	0	160

 Perforations:  
 Type perforation Torch cut  
 Size perforation 1/4" wide x 3" long  
 From 120 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 160 feet



Date started 3-8-99 19\_\_\_\_\_  
 Date completed 3-9-99 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	-0-	15 min

9. WATER LEVEL  
 Static water level 66 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Charles Nyberg WELL Drilling  
Contractor  
 Address 1060 W. Basin RD  
Contractor  
Pahrump, NV 89048  
 Nevada contractor's license number issued by the State Contractor's Board 7434  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725  
 Signed Charles Nyberg  
By driller performing actual drilling on site or contractor  
 Date 3-10-99

