

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 75181
 Permit No. _____
 Basin. 162



NOTICE OF INTENT NO. 13008

1. OWNER Ramon & Lourdes Hernandez ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 211 W. Linda St. 1650 W. Sloan St.
Pahrump, NV Pahrump, NV

2. LOCATION NE 1/4 NW 1/4 Sec 20 T. 19S N/S R 53 E Nye County _____
 PERMIT NO. 29-384-06 29-384-06 Crystallaire Estates, Lot 211
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Soft sandy clay		4	32	23
Grey clay		32	38	6
Brown clay		33	112	74
Cemented gravel		112	116	4
Clay w/gravel	x	116	123	12
Brown clay		128	136	8
Clay & gravel	x	136	143	12
Brown clay	x	148	160	12

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From To
12 Inches 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>17#</u>	<u>.138</u>	<u>0</u>	<u>160</u>


Perforations:
 Type perforation Torch cut
 Size perforation z 1/2 wide x 3" long
 From _____ feet to _____ feet
 From 120 feet to 160 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Charles Nyberg Well Drilling Contractor
 Address 1060 W. Basin RD Contractor
Pahrump, NV 39048
 Nevada contractor's license number issued by the State Contractor's Board 7484
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
 Signed Charles Nyberg by C.R.D.
 By driller performing actual drilling on site or contractor
 Date 3-10-99



Date started 3-4-99, 19____
 Date completed 3-3-99, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>	<u>-0-</u>	<u>15 min</u>

