

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16954

1. OWNER Bill Moore ADDRESS AT WELL LOCATION Vacant
MAILING ADDRESS 265 Liliyn Henderson Nevc. 89015
2. LOCATION NE 1/4 SE 1/4 Sec. 35 T. 21 N/S R. 60 E. Clark County
PERMIT NO. 163-35-703-006 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Cemented Gravel		0	12	
Clay & Gravel		12	14	
Cemented Gravel		14	23	
Clay & Gravel		23	26	
Cemented Gravel		26	340	
Gravel & Water	xx	340	345	
Cemented Gravel		345	355	
Gravel & Water	xx	355	370	
Cemented Gravel		370	385	
Gravel & Water	xx	385	400	
Cemented Gravel		400	430	
Gravel & Water	xx	430	445	
Cemented Gravel		445	490	
Reddish Cemented Gravel		480	505	
Yellowish Cemented Gravel		505	520	
Reddish " " "		520	535	
Cemented Gravel		535	590	
Gravel & Water	xx	590	610	

8. WELL CONSTRUCTION
Depth Drilled 610 Feet Depth Cased 610 Feet
HOLE DIAMETER (BIT SIZE)
From To
12 1/4 Inches 0 Feet 50 Feet
9 7/8 Inches 50 Feet 610 Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	10
5 1/2"	PVC	SRD 21	+1	610

Perforations:
Type perforation 8x8 Factory
Size perforation 1/8 x 3 row
From 5.60 feet to 6.00 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: _____
Depth of Seal 60 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 31.8 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cool °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick Contractor
Address 5360 Bonita Vista Contractor
Las Vegas, Nev. 89129
Nevada contractor's license number 10062 issued by the State Contractor's Board.
Nevada driller's license number issued by the 552 Division of Water Resources, the on-site driller.
Signed V.H. Dimick By driller performing actual drilling on site or contractor
Date 3-10-99

Date started 2/26/99, 19____
Date completed 3/9/99, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

