WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75208
Permit No.
Basin 212

NOTICE OF INTENT NO. 15614

1. OWNER Bay Management Inc c/o Dames & Moore
MAILING ADDRESS 7715 Amigo St.
LV, NV 89119
ADDRESS AT WELL LOCATION BMI Ponds
Henderson NV

2. LOCATION NW ¼ SW ¼ Sec. 31 T. 21 N. R. 63 E. CLARK County
PERMIT NO. (Issued by Water Resources) 179-05-101-091 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Gravelly Sand	18.5	0	30	30
Clay muddy Creek		31	35	5

Date started Sept 5, 1998
Date completed Sept 5, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
8	0	35

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 1/2		1/4	0	35

Perforations:
Type perforation Factory Slotted
Size perforation 020
From 15 feet to 35 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 13
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 13 feet to 35 feet

9. WATER LEVEL
Static water level 18.5 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Compliance Drilling
Address (Contractor) P.O. Box 94136
Las Vegas NV 89193
Nevada contractor's license number issued by the State Contractor's Board 3357
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1357
Signed ____ (By driller performing actual drilling on site or contractor)
Date Sept 15, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. ~~12~~ 75208
Permit No.
Basin 212

NOTICE OF INTENT NO. 8214

1. OWNER Bex Management Inc c/o Dames & Moore
MAILING ADDRESS 7115 Amigo St.
LV NV 89119

ADDRESS AT WELL LOCATION BMI Ponds
Henderson NV

2. LOCATION NW ¼ SW ¼ Sec. 31 T. 21 N/S R. 63 E. CLARK County
PERMIT NO. (Issued by Water Resources) 179-05-501-001 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Sandy Gravel		0	31	31
Moderate Clay	19	31	35	4

Date started Sept 8, 1998
Date completed Sept 15, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 0 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
3	0	35

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 1/2		1/4	0	35

Perforations:
Type perforation Factory Slotted
Size perforation 020
From 15 feet to 35 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 13
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 13 feet to 35 feet

9. WATER LEVEL
Static water level 17 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Compliance Drilling Corp
Address (Contractor) P.O. Box 94136
Las Vegas NV 89193
Nevada contractor's license number issued by the State Contractor's Board 9527
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 12257
Signed (By driller performing actual drilling on site or contractor)
Date Sept 15, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627