

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 75223
Permit No. _____
Basin 218

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17133

1. OWNER American Pacific Corp. ADDRESS AT WELL LOCATION
MAILING ADDRESS 3770 Howard Hughes Pkwy. Southwest Corner of Gibson & American
Suite 300, Las Vegas, NV 89109 Pacific Dr., Henderson, NV
2. LOCATION NE 1/4 NE 1/4 Sec. 15 T. 22 N/S R. 62 E Clark County
PERMIT NO. 178-15-511-016
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel & Sand		0	12	
Silty Sand		12	20	
Sand		20	23	
Silt & Sand		23	27	
Clayey Silt		27	84	
Silty Sand		84	97	

8. WELL CONSTRUCTION
Depth Drilled 97 Feet Depth Cased 95 Feet
HOLE DIAMETER (BIT SIZE)
From 0 To 97
10 Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
4.5 _____ .237 0 75 Blank
4.5 _____ .237 75 95 Screen

Perforations:
Type perforation Slotted
Size perforation 0.020
From 75 feet to 95 feet
From _____ feet to _____ feet
Surface Seal: Yes No Seal Type:
Depth of Seal 71 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
x grout well
Gravel Packed: Yes No
From 71 feet to 97 feet

9. WATER LEVEL
Static water level 21.81 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Beylik Drilling, Inc. Contractor
Address 555 S. Harbor Blvd. Contractor
La Habra, CA 90631-6124
Nevada contractor's license number issued by the State Contractor's Board 007055A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2011
Signed Donald Stratton
By driller performing actual drilling on site or contractor
Date March 01, 1999

Date started January 12, 1999
Date completed January 13, 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

RECEIVED
99 MAR -5 PM 12:05
STATE ENGINEERS OFFICE
MWD 7547
RECEIVED
MAR 10 1999