

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 75224
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17133

1. OWNER American Pacific Corp. ADDRESS AT WELL LOCATION
MAILING ADDRESS 3770 Howard Hughes Pkwy. Southwest Corner of Gibson & American
Suite 300, Las Vegas, NV 89109 Pacific Dr., Henderson, NV

2. LOCATION NE 1/4 NE 1/4 Sec 15 T 22 N/S R 62 E Clark County

PERMIT NO. 178-15-511-016

Issued by Water Resources

Parcel No.

Subdivision Name

3. WORK PERFORMED

- New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE

- Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE

- Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel & Sand, Dry		0	12	
Silty Sand, Dry		12	20	
Sand, Dry		20	23	
Silty Sand		23	27	
Clayey Silt,				
Caliche layers		27	84	
Silty Sand, Wet		84	104	
Silt, Wet		104	108	
Silty Sand		108	115	
Clay, Moist		115	116	
Silt, Wet		116	129	
Silty Sand		129	145	
Gravel, Sand		145	155	
Silty Sand		155	162	
Gravel & Silty Sand		162	183	

8. WELL CONSTRUCTION

Depth Drilled 183 Feet Depth Cased 181 Feet

HOLE DIAMETER (BIT SIZE)

From 10 Inches To 181 Feet
Inches Feet
Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations: Type perforation Slotted
Size perforation 0.020

From 161 feet to 181 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No

Depth of Seal 153

Placement Method: Pumped
 Poured

Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 grout well

Gravel Packed: Yes No

From 153 feet to 183 feet

9. WATER LEVEL

Static water level 20.23 feet below land surface

Artesian flow G.P.M. P.S.I.

Water temperature °F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Beylik Drilling, Inc.

Contractor

Address 555 S. Harbor Blvd.

Contractor

La Habra, CA 90631-6124

Nevada contractor's license number 007055A
issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2011

Signed *Donald Spatcher*
By driller performing actual drilling on site or contractor

Date March 01, 1999

RECEIVED
MAR - 5 PM 12:05
STATE ENGINEERS OFFICE

Date started January 5, 1999

Date completed January 10, 1999

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)