

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15253

1. OWNER STEVEN KUNTZ ADDRESS AT WELL LOCATION SANTEE & IRON  
MAILING ADDRESS SANDY VALLEY  
2. LOCATION SW 1/4 SW 1/4 Sec. 23 T. 24 N. R. 56 E. CLARK County  
PERMIT NO. 200-23-401-021 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM		0	6	6
CLAY		6	32	26
CLAY		32	37	5
CLAY		37	58	21
CLAY		58	62	4
CLAY		62	84	22
CLAY	WB	84	88	4
CLAY & GRAVEL		88	96	8
CLAY	WB	96	103	7
CLAY		103	113	10
CLAY	WB	113	128	15
CLAY		128	135	7
CLAY	WB	135	140	5

8. WELL CONSTRUCTION  
Depth Drilled 140 Feet Depth Cased 140 Feet  
HOLE DIAMETER (BIT SIZE)  
From 10 5/8 Inches To 140 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>4.33</u>	<u>.316</u>	<u>0</u>	<u>140</u>

Perforations:  
Type perforation FACTORY SAW CUT  
Size perforation 1/2 INCH BY 3 INCH  
From 120 feet to 100 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 140 feet to 50 feet

9. WATER LEVEL  
Static water level: 76 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature COOL °F Quality \_\_\_\_\_

Date started 4-15 1999  
Date completed 4-19 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name BUDGET DRILLING CO. Contractor  
Address P.O. BOX 3505 Contractor  
PAHRUMP NV. 89041  
Nevada contractor's license number issued by the State Contractor's Board: 40020  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1573  
Signed Donnie Brown  
By driller performing actual drilling on site or contractor  
Date 4-19-99

