

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 75266  
 Permit No. \_\_\_\_\_  
 Basin 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16960

1. OWNER George Wells ADDRESS AT WELL LOCATION 9125 S. Monte Cristo Wy. Las Vegas, Nev. 89113  
 MAILING ADDRESS Same

2. LOCATION SE 1/4 NW 1/4 Sec. 22 T. 22 N/S R. 60 E Clark County \_\_\_\_\_  
 PERMIT NO. 176-22-201-006 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Yellowish Sand		585	600	
Reddish Cemented Gravel		600	750	
Yellowish " " "		750	760	
Reddish Cemented Gravel and Water	xx	760	780	
Cemented Gravel		780	892	

8. WELL CONSTRUCTION  
 Depth Drilled 892 Feet Depth Cased 892 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
6 1/4 Inches 585 Feet 892 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 1/2</u>	<u>PVC SRD 21</u>	<u>21</u>	<u>+1</u>	<u>892</u>

Perforations:  
 Type perforation Factory  
 Size perforation 3/16 x 4 row  
 From 760 feet to 892 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 555 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vernon H. Dimick Contractor  
 Address 5360 Bonita Vista Contractor  
Las Vegas, Nev. 89129

Nevada contractor's license number 10062 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 552 Division of Water Resources, the on-site driller.

Signed VH Dimick  
 By driller performing actual drilling on site or contractor  
 Date 4-20-99

Date started 4/12/99, 19\_\_\_\_  
 Date completed 4/19/99, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

