

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 75272
Permit No. 212
Basin. 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17131

1. OWNER American Pacific Corp. ADDRESS AT WELL LOCATION
MAILING ADDRESS 3770 Howard Hughes Pkwy. Southeast of US-95 and Warm Springs Rd.
Suite 300, Las Vegas, NV 89109 Henderson, NV
2. LOCATION SE 1/4 SW 1/4 Sec. 11 T 22 N/S R. 62 E Clark County
PERMIT NO. 178-11-501-005
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silty Gravel		0	20	20
Silty Sand		20	30	10
Silty Sand & Gravel		30	45	15
Sandy Clay & Caliche		45	190	145
Silty Sand		190	211	21

8. WELL CONSTRUCTION
Depth Drilled... Feet Depth Cased... Feet
HOLE DIAMETER (BIT SIZE)
From 10 Inches To 211 Feet
Inches Feet Feet
Inches Feet Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
4.5 .237 0 190 Blank
4.5 .237 190 210 Screen
Perforations:
Type perforation Slotted
Size perforation 0.020
From 190 feet to 210 feet
From... feet to... feet
From... feet to... feet
From... feet to... feet
From... feet to... feet
Surface Seal: Yes No Seal Type:
Depth of Seal... Neat Cement
Placement Method: Pumped Concrete Grout
 Poured
Gravel Packed: Yes No x grout well
From 187 feet to 211 feet

RECEIVED
99 MAR -5 PM 12:05
STATE ENGINEER'S OFFICE

Date started January 25, 1999
Date completed January 27, 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
Static water level... feet below land surface
Artesian flow... G.P.M. 1 P.S.I.
Water temperature... °F Quality...
10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Beylik Drilling, Inc. Contractor
Address 555 S. Harbor Blvd. Contractor
La Habra, CA 90631-6124
Nevada contractor's license number 007055A issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2011
Signed Donald C. Stratta
By driller performing actual drilling on site or contractor
Date March 01, 1999