

WHITE--DIVISION OF WATER RESOURCES
 CANARY--CLIENT'S COPY
 PINK--WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 75275
 Permit No. _____
 Basin 212

NOTICE OF INTENT NO. 17131

1. OWNER American Pacific Corp. ADDRESS AT WELL LOCATION Southeast of US-95 and Warm Springs Rd. Henderson, NV
 MAILING ADDRESS 3770 Howard Hughes Pkwy. Suite 300, Las Vegas, NV 89109
 2. LOCATION SE 1/4 SW 1/4 Sec. 11 T. 22 N/S R. 62 E Clark County
 PERMIT NO. 178-11-501-005
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silty Gravel		0	20	20
Silty Sand		20	30	10
Silty Gravel & Sand		30	45	15
Sandy Clay & Caliche		45	190	145
Silty Sand		190	208	18
Silty Sand & Clay		208	223	15
Silty Sand		223	255	32

8. WELL CONSTRUCTION
 Depth Drilled 255 Feet Depth Cased 250 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 255 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5		.237	0	230 Blank
4.5		.237	230	250 Screen

Perforations:
 Type perforation Slotted
 Size perforation 0.020
 From 230 feet to 250 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 218
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 x grout well
 Gravel Packed: Yes No
 From 218 feet to 255 feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. 10 P.S.I.
 Water temperature _____ °F Quality _____

Date started January 19, 1999
 Date completed January 24, 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Beylik Drilling, Inc. Contractor
 Address 555 S. Harbor Blvd. La Habra, CA 90631-6124 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 007055A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2011
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date March 01, 1999

RECEIVED
 39 MAR -5 PM 12:05
 STATE ENGINEERS OFFICE

