WELL NO. MW DX-121

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75278
Permit No.
Basin 212

NOTICE OF INTENT NO. 17133

1. OWNER American Pacific Corp.
MAILING ADDRESS 3770 Howard Hughes Pkwy. Suite 300, Las Vegas, NV 89109

ADDRESS AT WELL LOCATION Southwest corner of Gibson & American Pacific Dr. Henderson, NV

2. LOCATION NE ¼ NE ¼ Sec. 15 T. 22 N/S R. 62 E. Clark County

PERMIT NO. (Issued by Water Resources) | Parcel No. 178-15-511-016 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel & Sand		0	12	
Silty Sand		12	20	
Sand		20	23	
Silty Sand		23	27	
Clayey Silt, Caliche		27	84	
Silty Sand		84	104	
Silt		104	108	
Silty Sand		108	115	
Clay		115	116	
Silt		116	129	
Silty Sand		129	144	

RECEIVED 99 MAR -5 PM 12:05 STATE ENGINEERS OFFICE

Date started January 11, 19 99
Date completed January 12, 19 99

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 144 Feet Depth Cased 141 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10	0	144

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5		.237	0	121 Blank
4.5		.237	121	141 Screen

Perforations:
Type perforation Slotted
Size perforation 0.020
From 121 feet to 141 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☐ Concrete Grout
x grout well

Gravel Packed: ☒ Yes ☐ No
From 116 feet to 144 feet

9. WATER LEVEL
Static water level 20.06 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Beylik Drilling, Inc. (Contractor)
Address 555 S. Harbor Blvd. (Contractor)
La Habra, CA 90631-6124

Nevada contractor's license number issued by the State Contractor's Board 007055A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2011

Signed Donald A. Stratton (By driller performing actual drilling on site or contractor)
Date March 01, 1999

I

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627