

OFFICE USE ONLY
 Log No. 75211
 Permit No. 9B
 Basin. Key
 NOTICE OF INTENT NO. 22918

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Larry & Renee Erwin
 MAILING ADDRESS P.O. Box 60421
Reno, NV 89506
 ADDRESS AT WELL LOCATION 2200 Argonaught Way
Reno, NV 89506
 2. LOCATION SE 1/4 SE 1/4 Sec. 26 T. 22 N. 19 E. Washoe County
 PERMIT NO. N/A Issued by Water Resources 079-460-15 Parcel No. Red Rock Estates # 278 Part 4 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	28	
Lt. Brown Clay w/DG		28	91	
Granite		91	94	
Clay		94	135	
DG		135	142	
Red Clay		142	144	
Brown Clay		144	155	
Granite	X	155	420	

8. WELL CONSTRUCTION
 Depth Drilled 420 Feet Depth Cased 420 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 420
9 7/8 Inches 0 Feet 420 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	14	.188	-1	420

Perforations:
 Type perforation Mill Slot
 Size perforation 1/8 x 3
 From 200 feet to 220 feet
 From 260 feet to 280 feet
 From 300 feet to 320 feet
 From 340 feet to 400 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50+ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 420 feet

9. WATER LEVEL
 Static water level 142 feet below land surface
 Artesian flow none G.P.M. none P.S.I.
 Water temperature cool °F Quality good

Date started 3-30-99, 19____
 Date completed 4-10-99, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
Approx	30	410	3

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name MILLER & SONS DRILLING CO. Contractor
 Address P.O. Box 8056 Contractor
Reno, NV 89507
 Nevada contractor's license number 037915
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1418
 Division of Water Resources, the on-site driller
 Signed Renee Miller
 By driller performing actual drilling on site or contractor
 Date 4-16-99

RECEIVED
 99 MAY 25 AM 9:52
 STATE ENGINEER'S OFFICE