

212

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 75295
Permit No. _____
Basin. 85

MO-16-88
PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30138

1. OWNER Newmont Gold Co. ADDRESS AT WELL LOCATION At Ualmy Area
 MAILING ADDRESS P.O. Box 388 West of Lone tree pit 1 mile
Ualmy, Nevada 89438

2. LOCATION N.W. 1/4 SE 1/4 Sec. 16 T. 34 N. S. R. 42 E Humboldt County

PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Alluvium (Clay Gravel)</u>		<u>0</u>	<u>315'</u>	<u>315'</u>
<u>Bed Rock</u>		<u>315'</u>	<u>600'</u>	<u>285'</u>
<u>Neat cement 8 cement</u>		<u>0</u>	<u>20'</u>	<u>20'</u>
<u>8 w 80</u>				
<u>Red Gravel Sand 14</u>		<u>560</u>	<u>600'</u>	<u>40'</u>
<u>Abandonite 29 bags</u>		<u>50'</u>	<u>560'</u>	<u>510'</u>
<u>Cement 10 bags</u>		<u>0'</u>	<u>50'</u>	<u>50'</u>

8. WELL CONSTRUCTION
 Depth Drilled 410 600 Feet Depth Cased 690 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>12 1/2</u> Inches	<u>0</u> Feet	<u>20</u> Feet
<u>6 1/2</u> Inches	<u>20</u> Feet	<u>600</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8"</u>		<u>1/2" wall</u>	<u>0'</u>	<u>20'</u>
<u>2 1/2"</u>	<u>Blank</u>	<u>1/4" wall</u>	<u>20</u>	<u>580'</u>
<u>2 1/2"</u>	<u>Screen</u>	<u>1/4" wall</u>	<u>580'</u>	<u>580</u>
<u>2 1/2"</u>	<u>Blank</u>	<u>1/4" wall</u>	<u>580</u>	<u>600'</u>

Perforations:
 Type perforation Horiz. Slots
 Size perforation 8 slots

From 560 feet to 580 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50'
 Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 560 feet to 600 feet

9. WATER LEVEL
 Static water level 550' feet below land surface
 Artesian flow NA G.P.M. NA P.S.I.
 Water temperature 60.1 °F Quality Clean

Date started 1-5- 1999
 Date completed 1-9- 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>500</u>	<u>2</u>	<u>0</u>	<u>5 min</u>
<u>600</u>	<u>3</u>	<u>50</u>	<u>5 min</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Shalund Drilling Co Contractor
 Address 605 Union Pacific Way Contractor
P.O. Box 2748 Elko, Nevada 89803

Nevada contractor's license number issued by the State Contractor's Board 0030823
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2100

Signed Shawn Taylor
 By driller performing actual drilling on site or contractor
 Date 1-10-99