

212

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 75296
 Permit No. _____
 Basin _____

30282

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30282

MO168A

1. OWNER Newmont Gold Co.
 MAILING ADDRESS PO Box 388
Valmy, Nevada 89438

ADDRESS AT WELL LOCATION At Valmy west of lone tree pit 1 mile

2. LOCATION NW 1/4 SE 1/4 Sec 16 T 34 N R 42 E Humboldt County

PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Alluvium</u>		<u>0</u>	<u>200'</u>	<u>200'</u>
<u>Neat Cement 8 bags</u> <u>8-60</u>		<u>0</u>	<u>20</u>	<u>20'</u>
<u>Sand 18 bags</u>		<u>160</u>	<u>200'</u>	<u>40'</u>
<u>Abandonite 5 bags</u>		<u>160</u>	<u>110'</u>	<u>110'</u>
<u>Cement Seal 10 bags</u>		<u>0'</u>	<u>50'</u>	<u>50'</u>

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200' Feet

HOLE DIAMETER (BIT SIZE)
 From 12 1/2" Inches 0 Feet 20 Feet
 To 6 1/2" Inches 20' Feet 200' Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/8"</u>		<u>1/4" wall</u>	<u>0</u>	<u>20'</u>
<u>2 1/2"</u>	<u>Blank</u>	<u>1/4" wall</u>	<u>20</u>	<u>160'</u>
<u>2 1/2"</u>	<u>Screen</u>	<u>1/4" wall</u>	<u>160</u>	<u>180'</u>
<u>2 1/2"</u>	<u>Blank</u>	<u>1/4" wall</u>	<u>180</u>	<u>200'</u>

Perforations:
 Type perforation 1/2 slot
 Size perforation 5/8" slots
 From 160' feet to 180' feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50'
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 200' feet to 160' feet

9. WATER LEVEL
 Static water level NA feet below land surface
 Artesian flow NA G.P.M. NA P.S.I.
 Water temperature NA °F Quality NA

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name SKlund Drilling Co Contractor
 Address PO Box 2748 605 Union Pacific way Contractor
SIKO Nevada 89803
 Nevada contractor's license number issued by the State Contractor's Board: CO30823
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: M-2100
 Signed Shawn A. Taylor
 By driller performing actual drilling on site or contractor
 Date 1-15-99

Date started 1-13-99, 1999
 Date completed 1-14-99, 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>NA</u>		

Plugged by Well Log 112104