WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75301
Permit No.
Basin 212

NOTICE OF INTENT NO. 18505

1. OWNER SECOR c/o TOSCO Marketing
MAILING ADDRESS 1500 North Priest Drive
Tempe, AZ 85281

ADDRESS AT WELL LOCATION 2300 South Las Vegas Boulevard, Las Vegas, NV

2. LOCATION SE 1/4 SE 1/4 Sec. 4 T 21S N/S R 61E E Clark County
PERMIT NO. (Issued by Water Resources) | Parcel No. 162-04-813-072 | Subdivision Name MW6

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other Auger

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Asphalt/Fill		0	2	2
Caliche		2	3.5	1.5
Gravelly clay		3.5	6	2.5
Caliche		6	7.5	1.5
Sandy silt		7.5	12	4.5
Gravelly clay		12	16	4

Date started 2/25/1999 , 19__
Date completed 2/25/1999 , 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRUCTION**
Depth Drilled 16 Feet Depth Cased 16 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	16	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.157	0	16

Perforations:
Type perforation Factory Slot
Size perforation 0.020
From 6 feet to 16 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 0-1'/1-4' bentonite
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 4 feet to 16 feet

9. **WATER LEVEL**
Static water level 7 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Thomas High c/o Converse Consultants
Contractor
Address 731 Pilot Road, Suite H
Contractor
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 48947
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869
Signed
By driller performing actual drilling on-site or contractor
Date 6/6/99

USE ADDITIONAL SHEETS IF NECESSARY