WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75325
Permit No.
Basin 212

NOTICE OF INTENT NO. 18603

1. OWNER CAINEU Fuel STORAGE FAC.
MAILING ADDRESS 5049 N. SLOAN LANE Las Vegas, Nevada
ADDRESS AT WELL LOCATION 5049 N. SLOAN LANE Las Vegas, Nevada

2. LOCATION SW SW ¼ Sec. 34 T. 19 N/S R. 62 E. CLARK County
PERMIT NO. Issued by Water Resources
Parcel No. 123-34-499-001
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BACKFILL		0	1	
Br. silty clay w/ sand, some angular gravels present		1	9	
Brown silty sand w/ clay and some gravel		9	12	
lt. brown silty sand poorly sorted, some gravels present		12	22	
Br. silty sand w/ angular gravels		22	30	
Brd silty clay w/ some sand and angular gravels		30	36	
lt. brown silty gravel w/ sand, trace of clay, gravels are angular		36	38	
Br. silty clay w/ some sand and gravels present, stiff caliche		38	42	
		42	48	
lt. brown sandy gravel w/ silt		48	56	
br. silty clay w/ some sand and sparse gravel, stiff		56	115	

Date started 2-24, 1999
Date completed 2-25, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 115 Feet Depth Cased 66 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	115 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2			0	66

Perforations:
Type perforation Sch 40 PVC
Size perforation .020
From 66 feet to 115 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 56
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 56 feet to 115 feet

9. WATER LEVEL
Static water level 87 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name The Verde Companies, Inc. Contractor
Address 301 W. Deer Valley Rd #7 Contractor
Phoenix, Arizona 85027
Nevada contractor's license number issued by the State Contractor's Board 41809
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2070
Signed John Manley
By driller performing actual drilling on site or contractor
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627