WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75366
Permit No.
Basin 212

NOTICE OF INTENT NO. 15615

1. OWNER Melvin Shapiro/AL PHILLIPS Cleaners
MAILING ADDRESS 3250 Ali Baba Lane LV. Nv 89118
ADDRESS AT WELL LOCATION 3100 W. Sahara Las Vegas, Nev.

2. LOCATION ¼ SW ¼ Sec. 5 T. 21 N/S R. 61 E. Clark County
PERMIT NO. (Issued by Water Resources) 16205402001 (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Asphalt | | 0 | 6" | 0.5 |
| Subgrade | | 6" | 12" | 0.5 |
| Silty Clay | | 12" | 8 | 7.0 |
| Caliche | | 8.0 | 10.0 | 2.0 |
| Silty Clay Sand. | 12.5 | 10 | 25 | 15' |

Received APR 6 1999

Date started Sept 23, 1998
Date completed , 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| | | | |

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 6 Inches | 0 Feet | 25 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2 1/4 | | 1/8 | 0 | 25 |

Perforations:
Type perforation Factory Slot
Size perforation 070
From 10 feet to 25' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 6
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 8 feet to 25' feet

9. WATER LEVEL
Static water level 12.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Compliance Drilling (Contractor)
Address P.O. Box 94136 (Contractor)
Las Vegas, Nv 89193
Nevada contractor's license number issued by the State Contractor's Board 3327
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2057
Signed (By driller performing actual drilling on site or contractor)
Date Sept 25 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627