WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75373
Permit No.
Basin 19

NOTICE OF INTENT NO. 40436

1. OWNER ADOBE HTS
MAILING ADDRESS P.O. BOX 7316
INCLINE VILLAGE, NV 89452

ADDRESS AT WELL LOCATION SW CORNER OF ADOBE HEIGHTS ROAD AND PUEBLO DR

2. LOCATION NW 1/4 SE 1/4 Sec. 1 T 34N N/S R 54E E ELKO County
PERMIT NO. (Issued by Water Resources) 5-51D-29 (Parcel No.) ADOBE HEIGHTS (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	4	4
BROWN SILTSTONE		4	70	66
GREY SILTSTONE		70	240	170
GREY CLAY	X	240	600	360

RECEIVED 1999 APR 7 AM 11:55 NEVADA DIVISION OF WATER RESOURCES

Date started 3/25/99, 19__
Date completed 3/29/99, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		8

8. WELL CONSTRUCTION
Depth Drilled 600 Feet Depth Cased 600 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	600	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	15	.220	+1	600

Perforations:
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 580 feet to 600 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 600 feet

9. WATER LEVEL
Static water level 208 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC (Contractor)
Address P.O.BOX 850 (Contractor)
ELKO,NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed (By driller performing actual drilling on-site or contractor)
Date 4/2/99

USE ADDITIONAL SHEETS IF NECESSARY